

Sertifikat Certificate



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impctg@pupin.rs

SERTIFIKAT

Broj / Number: T 2401

☒ O PREGLEDU TIPa / Type examination

☐ POJEDINAČNI PREGLED / Single examination

Strana / Page: 1 / 2

Na zahtev naručioca /
By the request of purchaser:

Robert Bosch d.o.o. Omladinskih brigada 90E
11070 N. Beograd Srbija / Serbia

preduzeto je/
has been undertaken:

Kontrolisanje novog proizvoda /
The new product inspection

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report:

Broj / Number: T 2401

sa dokumentima u prilogu/
with attached documents:

- Uputstvo za korišćenje / User's manual
- Uputstvo za instaliranje / Installation instruction;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaji o ispitivanju DVGW B 23/11/4232 EU i IMP CGT T 2401 / Test reports DVGW B 23/11/4232 EU i IMP CGT T 2401

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection:

GASNI KONDENZACIONI KOTAO /
GAS CONDENSING BOILER

proizveden od /
manufactured by:

Bosch Thermotechnik GmbH Junkersstase 20-24, D-73249 Wernau Nemačka

oznaka - tip - serija /
mark - type - series:

Bosch Condens GC5700iW ... / GC7800iW ...
vrsta/type: B₂₃, B_{33(X)}, B_{53P}, C_{13(X)}, C_{33(X)}, C_{43(X)}, C_{53(X)},
C_{63(X)}, C_{83(X)}, C_{93(X)}
kategorija/category: II_{2H3P}

kako je specificirano u Prilogu
A, zadovoljava zahteve
navedene u /
as specified in the Annex A, meets
the requirements listed in:

- Pravilnik o zahtevima za projektovanje, izradu i ocenjivanje usaglašenosti gasnih aparata ("Sl. gl. RS", br. 41/2015)
- SRPS EN 15502-2-1:2017

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012 and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.
Ocenjivanje sprovedeno / Evaluation performed from 21.12.2023. - 01. 03. 2024.

izdat od / issued by:


INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE
Kristina Petković dipl.maš.inž.

mesto, datum / place, date:

Beograd, 01.03.2024.



Ime, Prezime / Name, Surname



Sertifikat Certificate



И 048 23

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs

Prilog A / Annex A

Broj / Number: T 2401

Strana / Page: 2 / 2

oznaka - tip - serija /
mark - type - series :

Bosch Condens GC5700iW ... / GC7800iW ...

vrsta/type: B₂₃, B_{33(X)}, B_{53P}, C_{13(X)}, C_{33(X)}, C_{43(X)}, C_{53(X)},

C_{63(X)}, C_{83(X)}, C_{93(X)}

kategorija/category: II_{2H3P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
Bosch Condens ...		
... GC5700iW 24/30 C 23 ... GC7800iW 24/30 C 23	$Q_n = 3,1 \div 24,5 \text{ kW}$ $P_n = 3,0 \div 24,0 \text{ kW}^1$ $P_n = 3,4 \div 25,0 \text{ kW}^2$	za grejanje i toplu sanitarnu vodu / for heating and domestic hot water
... GC5700iW 30/30 C 23	$Q_n = 3,0 \div 30,2 \text{ kW}$ $P_n = 3,0 \div 29,6 \text{ kW}^1$ $P_n = 3,2 \div 31,1 \text{ kW}^2$	
... GC5700iW 35/35 C 23	$Q_n = 5,1 \div 34,4 \text{ kW}$ $P_n = 5,0 \div 33,6 \text{ kW}^1$ $P_n = 5,5 \div 35,0 \text{ kW}^2$	
... GC5700iW 24 P 23	$Q_n = 3,1 \div 24,5 \text{ kW}$ $P_n = 3,0 \div 24,0 \text{ kW}^1$ $P_n = 3,4 \div 25,0 \text{ kW}^2$	
... GC5700iW 35 P 23	$Q_n = 5,1 \div 34,4 \text{ kW}$ $P_n = 5,0 \div 33,6 \text{ kW}^1$ $P_n = 5,5 \div 35,0 \text{ kW}^2$	
... GC5700iW 45 P 23	$Q_n = 6,3 \div 43,5 \text{ kW}$ $P_n = 6,2 \div 42,6 \text{ kW}^1$ $P_n = 6,8 \div 44,4 \text{ kW}^2$	
... GC5700iW 50 H 23	$Q_n = 6,3 \div 48,9 \text{ kW}$ $P_n = 6,2 \div 47,8 \text{ kW}^1$ $P_n = 6,8 \div 49,8 \text{ kW}^2$	

1. **Za** / for 80 / 60 °C

2. **Za** / for 50 / 30 °C

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /
Any changes on the device must be reported to the issuer of this document

Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja
Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one
year within the assessment of the Declaration of Conformity with the type!